Report of Inspection/Test

Annual Extinguisher

March 03, 2010

Cofessco FIRE PROTECTION
Muskegon (231) 726-2396 Grand Rapids (616) 243-6419
Holland (616) 396-6715 Kalamazoo (269) 226-2470
411 Ottawa Street, Muskegon, MI 49442

Property
ABC Company
123 Main Street SW
Anytown, MI 45678

Jenny Tutone
(616)867-5309

Owner/Agent
ABC Company
123 Main Street SW
Anytown, MI 45678

ABC Company
(616)867-5309

Conducted by: Extinguisher Technician
Inspection Ref: 15069

Fire Extinguisher Inspection List

Item #	Equip ID	Location	Size	Type	Manufacturer Model	Serial #	Inspection - Service								
							Hydro Test	6 Year Insp	Weight	Bracket	Gauge	Pull Pin	Signage	Collar	Hose
1	ABC1	Hall by Break Room	5 lb	ABC	Amerex 402	2436419	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok
2	ABC2	Hall Outside Server Room	5 lb	Halotron	Amerex 397	3966715	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	NA
3	ABC3	Entrance to Shop Area	10 lb	ABC	Amerex 456	7262396	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok
4	ABC4	Shop NW	10 lb	ABC	Amerex 441	2262470	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok
5	ABC5	Outside Electrical Room	10 lb	CO2	Amerex 330	5323801	Ok	NA	Ok	Ok	NA	Ok	Ok	Ok	Ok
6	ABC6	Shop SW	10 lb	ABC	Amerex 456	7220905	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok
7	ABC7	Shop SE	10 lb	ABC	Amerex 456	8675309	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok
8	ABC8	By Shipping Dock	10 lb	ABC	Amerex 441	9681407	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok
9	ABC9	Shop NE	10 lb	ABC	Amerex 456	2437604	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok

Inspection Service Summary	Number of Items	9	S	Items serviced									
			X	Items requiring service									